

From: [Walden, Ted](#)
To: 5 U.S.C. § 552 (b)(6) Personal Privacy
Subject: FW: Fuel Tank
Date: Tuesday, June 22, 2021 6:00:00 PM
Attachments: [SPCC Blue Brochure.pdf](#)

5 U.S.C. § 552 (b)(6) Personal Privacy

Hi. Thank you for the information. This facility is likely regulated under EPA's SPCC regulation (40 CFR Part 112). I'm hoping that we can get someone out there in the next 60-days or so to look at the facility. Might be less than 60-days might be more, but we will have someone out to look at SPCC compliance at this facility.

I've attached a brochure that summarizes the SPCC regulation. This regulation is enforced by EPA and EPA only. States can have their own similar type oil spill prevention regulation but North Carolina does not. Local zoning and fire codes could certainly be applicable for this facility depending on the local/state agency.

Link to NCDEQ information regarding ASTs:

<https://deq.nc.gov/about/divisions/waste-management/ust/ast-program>

Regards,

Ted Walden, FRP/SPCC Coordinator
Emergency Response, Removal, Prevention and Preparedness Branch
U.S. Environmental Protection Agency, Region 4
[61 Forsyth Street SW | Atlanta, Georgia](#) | 30303
office: [404-562-8752](tel:404-562-8752)
walden.ted@epa.gov
epa.gov/oilspill

From: Barrino, Reginald <Barrino.Reginald@epa.gov>
Sent: Thursday, June 17, 2021 9:29 AM
To: Walden, Ted <Walden.Ted@epa.gov>
Subject: FW: Fuel Tank

Hi Ted,

Can you offer any assistance to 5 U.S.C. § 552 (b)(6) Personal Privacy? He is concerned of inadequate SPCC measures.

Thank you,

Reginald

From: 5 U.S.C. § 552 (b)(6) Personal Privacy

Sent: Wednesday, June 16, 2021 3:50 PM

To: Digaetano, Laurie <Benton-Digaetano.Laurie@epa.gov>

Subject: Fuel Tank

Hello Ms Benton-Digaetano,

I'm not sure if you are the right person to contact about this issue. If not, could you point me in the right direction? I am writing to inform the EPA about a possible violation regarding an above ground storage tank 5 U.S.C. § 552 (b)(6) Personal Privacy.

There is a 12,000 gal diesel tank that was installed where a previously permitted 3,000 gal tank used to be. The spill containment dike is sized for the 3,000 gal tank and my concern is that if there is a release from this tank that the fuel will flow directly into the Intracoastal Waterway which is only 53' away. I've attached permit documents I received from a FOIA request to the county. I already tried to get county code enforcement to look at the tank but they refuse to send anyone out to the site. I've also included a photo of the existing tank to show the size difference between what was permitted and what is there. Thank you again for any assistance you can provide in this matter.

Sincerely,

5 U.S.C. § 552 (b)(6) Personal Privacy

